

FITNESS CERTIFICATE


To be filled by the inspecting Officer (Asst.Engineer)

(Re:G.O.Ms.20/70/PWD Dt. 23.01.1970)

- 1 Name of the school : Alphonsa English Medium School
- 2 Name of the Officer : Ajith Kumar v Assistant Engineer
- 3 Location with name of Education : Keezhpally, Thalassery Education District, Iritty Education District/Sub. District : Sub District
- 4 Classification of Building as specified in column 4 of the application for fitness certificate and size : (All dimensions are in metres)
Ground Floor
(1) 55.07 x 13.26 x 3.70
(2) 45.47 x 08.44 x 3.70
(3) 19.92 x 05.54 x 3.70
(4) 09.40 x 08.03 x 3.70
(5) 06.43 x 02.28 x 3.70
First Floor
(6) 46.27 x 08.86 x 3.70
(7) 06.53 x 03.61 x 3.70
(8) 15.03 x 13.35 x 3.70
(9) 02.21 x 01.63 x 3.70
(10) 19.92 x 03.82 x 3.70
Second Floor
(11) 48.25 x 08.44 x 3.70
(12) 06.53 x 03.61 x 3.70
(13) 03.41 x 08.55 x 3.70
- 5 Period for which the certificate is issued : 01/06/2026 to 31/05/2027
- 6 Nature of defects, if any :
 - a) Foundation and basement
 - b) Superstructure
 - c) Doors and Windows
 - d) Wood work wrought and put up : NIL
 - e) Roof
 - f) Flooring
 - g) Miscellaneous (Cracks, etc.)
- 7 Any major defects noticed which will render the building unsafe in any manner : No
- 8 Whether maintenance works have been done properly : yes
- 9 Whether the structure is sound or not for conducting classes : Yes, sound for conducting classes under normal weather and wind condition

Note:

- 1 The stability of the structure should be examined also with reference to location, altitude, intensity of wind, exposure of flood etc.
- 2 Any additional observations if deemed necessary for the certificate may be furnished separately with this certificate.
 1. This certificate is applicable only to safety related to civil construction. Separate certificates for fire safety and safety of electrical installations, electrical lines/conduits shall be obtained from the concerned departments.
 2. Maintenance of the school premises should be done periodically. The inspecting officer is not liable for any unfortunate accidents in the school premises due to lack of security or periodic maintenance.


ASSISTANT ENGINEER (I.S.G.)
ARALAM GRAMA PANCHAYAT
P.O. PAYAM - 670704

3. This certificate is only for the structural safety of the classrooms mentioned in this certificate. It does not cover safety in laboratories, kitchens, etc.
4. For any new construction in the school compound, it should be intimated and a permit should be obtained from LSGI. Safety measures such as barricades must be ensured.
5. Internal wiring of the school should be verified by a registered /Approved Electrician before conducting classes
6. This fitness certificate is issued provisionally based on circular No: GEDN-M1/188/2025-G.EDN by General Education(M)Department Thiruvananthapuram : 13/05/2026 and Circular No - LSGD/2037/2026-EW3, Chief Engineer, Principal Directorate, LSGD. The head of the institution should follow all the instructions in Circular No M3/347/2019- HEALTH Dated : 09/11/2025 Health & Family Welfare (M) Department, Government of Kerala and copies of necessary NOC/Verification reports, after rectification works in schools if any should hand over to this office within three months.

CERTIFICATE

Certified that the school building was inspected by me on 22/05/2026 and found to be fit to conduct classes, for the period up to 01/06/2026 to 31/05/2027 for the reasons stated above.


Place : Edoor
Date : 30/05/2026

(Seal)

Assistant Engineer



ASSISTANT ENGINEER (L.S.E.)
ARALAM GRAMA PANCHAYAT
P.O. PAYAM - 670704


PRINCIPAL
ALPHONSA E.M. SCHOOL
KEEZHPALLY, KANNUR, KERALA - 670704

